



Member of the FM Global Group

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

FCS-MBT (Megablock Terminator) Fieldbus

NI/I/2/ABCD/ T4 Ta = 70°C - 500-948

I / 2 / IIC / T4 Ta = 70°C - 500-948

Special Condition of Use

1. The equipment shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.

FCS-MB2ab, FCS-MB4ab, FCS-MB8ab, FCS-MB10ab, FCS-MB12ab, F200b-F216b, F118b, F100 (Megablock Terminator) Fieldbus

NI/I/2/ABCD/ T4 Ta = 70°C -500-275

I / 2 / IIC / T4 Ta = 70°C - 500-275

a = blank or -SG and/ or -T

b = blank, -PC, -PD

Special Condition of Use

1. The equipment shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.

Equipment Ratings:

Nonincendive for use in Class I, Division 2, Groups A, B, C and D, and Class I, Zone 2, Group IIC indoor hazardous locations.

FM Approved for:

Relcom Incorporated
2221 Yew Street
Forest Grove, OR 97116



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3611	1999
Class 3810	1989

Original Project ID: 3013269

Approval Granted: August 12, 2002

Subsequent Revision Reports / Date Approval Amended

040422
051017

May 7, 2004

JAN 5, 2006

FM Approvals LLC

Robert L. Martell, Jr.
Assistant Vice President

JAN 5, 2006
Date