



FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

Member of the FM Global Group

CERTIFICATE OF COMPLIANCE

HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

F801. Field Bus Supply Module and Carriers.

NI / I / 2 / ABCD / T4 Ta = 65 °C

I / 2 / IIC / T4 Ta = 65 °C

Fieldbus Supply Module and Carriers Combination Part Numbers: F822-PS, F822-PS-NR, F822-PC, F822-PC-NR, F880-PS, F880-PS-NR, F880-PC, F880-PC-NR, F880-LS, F880-LS-NR, F880-LC, F880-LC-NR, F880-RS, F880-RS-NR, F880-RC, F880-RC-NR, F882-PS, F882-PS-NR, F882-PC, F882-PC-NR, F890-PS, F890-PC, F890-PS-NR, F890-PC-NR, F892-PS, F892-PC, F892-PS-NR, F892-PC-NR.

Carrier Part Numbers: F822-CAa, F880-CAa, F880-CLa, F880-CRa, F882-CAa, F890-CAa, F892-CAa.

Where a = None, -PC, or -PS.

Fieldbus Power Supply Module: F801

Special Condition for use:

- 1. The F801 Field Bus Supply Module and Carriers shall be installed in compliance with the enclosure, mounting, and spacing, and segregation requirement of the ultimate application, including a tool removable cover.*
- 2. When installed in Division 2 Hazardous (classified) locations, a warning label must be prominently affixed near the unit(s) which warns that the cables must not be removed or inserted unless the area is known to be non-hazardous.*
- 3. It is the responsibility of the manufacturer to provide warning markings in French where required by local jurisdictions.*

Equipment Ratings:

Nonincendive for Class I, Division 2, Groups A, B, C, and D and Class I, Zone 2, Group IIC hazardous (classified) locations.

FM Approved for:

Relcom, Inc.
Forest Grove, OR97116



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

C22.2 No. 213 1987
C22.2 No. 142 1987

Original Project ID: 3025124C

Approval Granted: May 1, 2007

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
100526	June 11, 2010		

FM Approvals LLC

J. E. Marquedant
Group Manager, Electrical

11 June 2010
Date